

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. (38)

Dated: 8/6/2023

It is certified that an inspection team headed by Dr. Yogendra Singh.

(Name of Officers with designation) from MS (CHC Gajraula)

(Name of Department/ Office) inspected the Noble Public School, GAJRAULA

(Name & Address of the school) on 08/06/2023 (date of inspection) and found that the Noble Public School. (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 08/06/2024

Signature with Seal: 

Name

Designation

Name & Address of the Office / Department : MS (CHC Gajraula)

To

Noble Public School
GAJRAULA (Amroha)

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



SRI GANESH ANALYTICAL LAB

AN ISO 9001 : 2015 CERTIFIED LAB (REGISTERED IN MSME : GOVT. OF INDIA)

1111, KRISHNA NAGAR, MEERUT ROAD, GHAZIABAD-201003 (U.P.), INDIA

E-mail: srganeshanalytical.lab@gmail.com Ph.:0120-2712103, Mob: 9211842818, 9911702615

Our Ref. No. Date..... Your Ref.No. Dated:.....

TEST REPORT

Ref No.: SGAL/22-23/11856

Noble Public School
Unit of Noble education society,
Delhi Road, Gajraula,
Uttar Pradesh

1. Order No 11856
2. Date of Receipt 08/06/2023
3. Description One sample of R.O. Water
4. Quantity Approx. 1 ltr.
5. Test Required As mentioned below

Date: 09/06/2023

S. No.	Tested Parameter	Acceptable Limit	Result	Remarks
Physical Analysis				As per the following tests conducted in accordance with IS:10500-2012, the provided sample is suitable for usage in drinking purposes.
1.	Appearance	Clear	Clear	
2.	Odor	Odorless	Odorless	
3.	Total Solids (in mg/l)		159.88	
4.	Total Dissolved Solids (in mg/l)	Less than 500 ppm	156.32	
5.	Total Suspended Solids (in mg/l)		3.56	
6.	pH	6.50 – 8.50	7.14	
Chemical Analysis				
1.	Total Alkalinity (in mg/l)	Less than 250 ppm	84.21	
2.	Total Chlorides Content as Cl (in mg/l)	Less than 250 ppm	74.68	
3.	Total Sulphates Content as SO ₄ (in mg/l)	Less than 200 ppm	14.27	
4.	Total Iron Content as Fe (in mg/l)	Less than 0.3 ppm	0.02	
5.	Total Calcium Content as Ca (in mg/l)	Less than 75 ppm	24.77	
6.	Total Magnesium Content as Mg (in mg/l)	Less than 30 ppm	12.94	
7.	Total Nitrates as NO ₃ (in mg/l)	Less than 45 ppm	2.73	
8.	Total Hardness as CaCO ₃ (in mg/l)	Less than 200 ppm	102.91	
9.	Total Ammonia Content as NH ₃ (in mg/l)	Less than 0.5 ppm	Not Traceable	
10.	Total Silica Content as SiO ₂ (in mg/l)		0.01	

For SRI GANESH ANALYTICAL LAB

Pabhat Kumar

Manager

1. Sample(s) not collected by us unless otherwise specified.
2. Perishable samples will be destroyed after testing after 10 days.
3. The result listed above refer only to the tested samples.
4. Total liability is limited to the invoice amount only.
5. This report is not to be reproduced and cannot be used as evidence in the court of law without our permission in writing. p